



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

### General Comments

Inspection report emailed to Norma Lopez - Cao on 06/02/2022.

At the time of inspection no shower on site was observed.

Email Address(es): nlopez-cao@dadeschools.net;  
drcynthiahannah@dadeschools.net;  
jaybolton@dadeschools.net;  
jware@dadeschools.net;  
ipalacio@dadeschools.net

### Violations Comments

#### Violation #5. Maintenance & Repair

Observed damaged ceiling tiles due roof leak in classrooms: 038 kindergarten, 042 kindergarten, 025 primary, 026 primary and 030 primary. Repair water leak and replace ceiling tiles.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

#### Violation #6. Lighting Standards

Observed three lights out of order in classroom: 030 primary. Repair ligths.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Cesar Martinez (085423)  
Inspector Contact Number: Work: (305) 623-3500 ex.  
Print Client Name:  
Date: 6/2/2022

Inspector Signature:

Handwritten signature of Cesar Martinez, consisting of the letters 'CM' in a stylized font.

Client Signature:

Handwritten signature of Charles Hadley, consisting of a stylized 'C' followed by a flourish.