

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Inspection report emailed to Norma Lopez- Cao on 06/02/2022.

At the time of inspection no shower on site was observed.

Email Address(es): nlopez-cao@dadeschools.net;
drcynthiahannah@dadeschools.net;
jaybolton@dadeschools.net;
jware@dadeschools.net;
ipalacio@dadeschools.net

Violations Comments

Violation #6. Lighting Standards

Observed lights out of order in classrooms: 401C, 502C and 302D. Repair lights.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Cesar Martinez (085423)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 6/2/2022

Inspector Signature:

CM

Client Signature:

[Handwritten Signature]