

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Inspection report emailed to Jordana Schneider on 08/09/2023.

The inspection result is satisfactory because water leaks were repaired and ceiling tiles were replaced at classrooms:037, 042, 021 and 030, also lights were repaired at classrooms: 021 and 030.
At the time of inspection no shower on site was observed.

Email Address(es): jschneider@dadeschools.net;
mwertz@dadeschools.net;
ipalacio@dadeschools.net;
wcabrera@dadeschools.net

Violations Comments

Violation #5. Maintenance & Repair

Observed broken floor tiles in bathroom 036. Repair floor tiles. Bathroom 036 is close, instead they are using bathroom 035 . W.O #4356026 was created to repair the bathroom.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Cesar Martinez (085423)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 8/9/2023

Inspector Signature:

CM

Client Signature:

CS